

120 FERN AVENUE
(SEE PLOT PLAN)

53.4 SAND & GRAVEL 8'

58

56

* OUTFALL MUST
BE 75' MIN
FROM FIELD

APPROX 120'
DRAINAGE BROOK
EASEMENT

EASEMENT
(NOTE)

INS

56

REVIEWED AND APPROVED *CS*
IN ACCORDANCE WITH
REQUIREMENTS OF THE
TOWN OF RYE, NEW HAMPSHIRE
10/4/84

J. L. Galan
J. F. Young
J. B. Phillips

SELECTMEN

DATE *10/4/84*

PERC TEST

DATE: 9/20/84

DEPTH OF HOLE: 30"

RATE OF PERC: 6 MIN/IN

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 675 SQ.FT.

PROPOSED SYSTEM: 25 x 30 FOR
750 SQ.FT. AREA PROVIDED

OK'D 4 BEDROOM
REVISION BY
EVAN
SEE NEW
NO NEW
FVAL

PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 55-14 FERN AVENUE
RYE, N.H.

APPLICANT


OWNER: ROBERT V. & DIANNE HIGGINS
120 FERN AVE
RYE, NH. 03870

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

William & Eva
Signed *10-11-84*
Date *10-11-84*

115829

APPLICANT: ANNE W. BIAŁOBRZESKI
247 LANDING ROAD
HAMPTON, N.H. 03842
DESIGNER PERMIT #348



DATE: 10/1/84

APPROVAL:

17A
SEE REVISION

LION HOMES
(SEE PLOT PLAN)

53.4 (SAND & GRAVEL) 8'

58

56

REVIEWED AND APPROVED
IN ACCORDANCE WITH
REQUIREMENTS OF THE
TOWN OF RYE, NEW HAMPSHIRE

APPROX FT
(NOTE)

58

56

58

DRAINAGE BROOK
EASEMENT

*M. Young
J.B. Phillips*

SELECTMEN

DATE

*cmthompson
10/19/84*

REVIEWED AND APPROVED
IN ACCORDANCE WITH THE
REQUIREMENTS OF THE
NEW HAMPSHIRE
WATER SUPPLY & POLLUTION
CONTROL COMMISSION

Signed *William E. Evans*

Date *10/30/84*

C.A. 115829

PERC TEST

DATE: 9/20/84

DEPTH OF HOLE: 30"

RATE OF PERC: 6 MIN/IN

DESIGN LOADING: 4 BEDROOMS

AREA REQUIRED: 900 SQ.FT.

PROPOSED SYSTEM: 25 x 40 FOR
1,000 SQ.FT. AREA PROVIDED

REVISED PLAN OF PROPOSED SEPTIC SYSTEM

LOCUS: LOT 55-14 FERN AVENUE
RYE, N.H.

SEE APPROVAL # 115829


OWNER: ROBERT V. & DIANNE HIGGINS
120 FERN AVE
RYE, NH. 03870

APPLICANT

APPLICANT: ANNE W. BIAŁOBRZESKI
247 LANDING ROAD
HAMPTON, N.H. 03842
DESIGNER PERMIT #348

DATE: 10/24/84

APPROVAL:



17